



Online Application No 23971

[I-21/140/2026-W&M Section]
GOVERNMENT OF INDIA/भारत सरकार
MINISTRY OF CONSUMER AFFAIRS, FOOD AND PUBLIC DISTRIBUTION
उपभोक्ता मामले, खाद्य एवं सार्वजनिक वितरण मंत्रालय
DEPARTMENT OF CONSUMER AFFAIRS/ उपभोक्ता मामले विभाग
LEGAL METROLOGY DIVISION/ विधिक मापविज्ञान प्रभाग

Krishi Bhawan/कृषि भवन, नई दिल्ली
Dated/दिनांक- : 27.05.2026.

Certificate of Approval of Model/ मॉडल का अनुमोदन प्रमाणपत्र

Whereas the Central Government, after considering the report submitted to it by the prescribed authority, is satisfied that the model described in the said report is in conformity with the provisions of the Legal Metrology Act, 2009 (1 of 2010) and the Legal Metrology (Approval of Models) Rules, 2011 and the said model is likely to maintain its accuracy over periods of sustained use and to render accurate service under varied conditions;

Now, therefore, in exercise of the powers conferred by section 22 of the Legal Metrology Act, 2009 (1 of 2010) read with sub-rule (6) of rule 8 and sub-rule (4) of rule 11 of the Legal Metrology (Approval of Models) Rules, 2011, as per Schedule Seventh of the Legal Metrology (General) Rules, 2011, the Central Government hereby issues the certificate of approval of the model of non-automatic weighing instrument with digital indication of series "SL-WB-III" and with brand name " SUN LIGHT PLUS" (hereinafter referred to as the said model), manufactured by M/s ADVANCED TECHNOLOGY SOLUTIONS, Krushi Nagar Plot no. 59, in front of Shri Chhatrapati Shahu, Madhyamik Vidhyalay, Krushi Nagar, Taluka and District. Parbhani - 431401, Maharashtra. and which is assigned the approval mark IND/09/26/254 (the picture of model is given below as figure 1);

Technical Data:

Type of Instrument	Electronic Weigh bridge type
Accuracy Class	Medium Accuracy (Class - III)
Maximum Capacity	40t
Minimum Capacity	200 kg
Verification Scale Interval	10 kg
Power Supply	230 VAC, 50 Hz
Display Unit	LED Display indicates the weighing result and LCD is for other information (Date ,Time,etc.)
Tare	Subtractive
Working Principle	Strain Gauge Type load cell based
Load Cell	Make -Appalto,, Model - ACB-D30, Class - C3, Cap - 30t
Software Version	v1.0.0
Checksum	e561468cd91caaa79a6a013c181ffe77931619814dbaaf4a be6e5d1b431532



Figure 1






Figure 2

Sealing is done by passing the sealing wire through the holes provided on the body of machine. A lead seal is put at the end of the wire for stamping purpose (a typical schematic diagram of sealing provision to prevent the fraudulent practices of the model is given above as Figure 2). A dip switch has also been provided in mother board/PCB to disable access to external calibration.

Further, in exercise of the power conferred by sub-rule (9) of rule 8 of the Legal Metrology (Approval of Models) Rules, 2011, the Central Government hereby declares that this certificate of approval of the said model shall also cover the weighing instruments of similar make, accuracy and performance of same series with capacity above 5t and up to 150t with number of verification scale interval (n) in the range of 500 to 10000 for 'e' value of 5g or more with 'e' value of 1×10^k , 2×10^k or 5×10^k , where k is a positive or negative whole number or equal to zero manufactured by the same manufacturer in accordance with the same principle, design and with the same materials with which, the said approved model has been manufactured.

[F.No. I-21/140/2026-W&M Section]



(Ashutosh Agarwal/आशुतोष अग्रवाल)
Director (Legal Metrology) to Govt. of India/ निदेशक (विधिक माप विज्ञान) भारत सरकार
Phone/दूरभाष 01123389489
Email/ई-मेल: dirwm-ca@nic.in